

Technical Specification



Product Code:EMTSDescription:Emergency Light Test Switch

	duceri	
	 30 60 180 MINUTES 	
-	Ô	•
	EMERGENCY LIGHTIN	5
SELE	CT TIMING PERIOD BY TURNIN	G KEY

General Information	n
---------------------	---

	Dimensions (m	m) 86 x 86 x 33	
	Mount	ing Optional Flush or Surface	;
	Warranty (Yea	urs) 3	
	Supply & Power		
	Supply Voltage (V AC)	220 - 240	
	Frequency (Hz)	50	
		240V AC @ 16A	
	Output Relay Rating	6A Fluorescent	
		10A Incandescent	
Accessories	EMTSK: Pack of 2 Spare Keys		
Features	Assists the testing of emergency lighting in Key activated with 4 pre-programmed test 10 Minutes, 30 Minutes, 60 Minutes & 180 Clear LED indication for duration test Optional audio buzzer alert for completion Compact design manufactured from antim	intervals minutes of duration test	

Unit 7 Target Park, Shawbank Road, Lakeside, Redditch B98 8YN United Kingdom **T:** +44 (0)1527 515150 | **F:** +44 (0)1527 515143 **E:** info@espuk.com | **W:** espuk.com

